




1. Install the Seeker+ in desired location
2. Connect CTs and voltage leads to the Seeker+
3. Seeker+ will indicate hookup status through 3 onboard LEDs



LED Indicators After Installation

GREEN, BLUE, YELLOW, OR ORANGE:

Installation is complete



During 2-Minute Countdown

-  **GREEN:** Recorder is hooked up correctly
-  **PURPLE:** CTs are inverted or on incorrect phase
-  **ORANGE:** Possible problem with hookup

This information and more can be found at:
info.powermonitors.com/seeker-plus-getting-started



QUICK START GUIDE



1. Install PMI View (see below) and enable Bluetooth (BLE) on your iOS or Windows device.
2. Start PMI View and let it discover every Seeker+ in the area.
3. Select a Seeker+, then update it to the latest firmware if prompted.
4. Download the recorded data into PMI View, upload it to PQ Canvass, and let Merlin™ dig through your data, answer your questions, and generate reports.

PMI Software

PMI View
iOS



PMI View
Windows



PQ Canvass



Merlin™



Have a PQ Question? Ask Merlin™—free.

Text your questions to (540) 383-3144 or email
askmerlin@powermonitors.com for answers
backed by IEEE standards and decades of PQ data.

Power Monitors, Inc.
www.powermonitors.com
Made in the USA